



LA Testing

5431 Industrial Drive Huntington Beach, CA 92649
Tel/Fax: (714) 828-4999 /
<http://www.LATesting.com> / gardengrovelab@latestesting.com

LA Testing Order: 331823967

Customer ID: PECN42

Customer PO:

Project ID:

Attention: Nate Seward, PE, CIH
Premier Environmental Consulting (PEC)
581 Knotty Pine Dr
Incline Village, NV 89451

Phone: (805) 432-4888

Fax:

Received Date: 12/01/2018 10:15 AM

Analysis Date: 12/01/2018

Collected Date: 11/30/2018

Project: S.H.E.S

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm ²)	(S/cc)
TEM-1 331823967-0001	MPR	1200.00	0.0744	0	None Detected	0	0	0.0043	<13.00	<0.0043
TEM-2 331823967-0002	Staff rm	1200.00	0.0744	0	None Detected	0	0	0.0043	<13.00	<0.0043
TEM-3 331823967-0003	Lower pod (1501)	1200.00	0.0744	0	None Detected	0	0	0.0043	<13.00	<0.0043
TEM-4 331823967-0004	Upper pod	1200.00	0.0744	0	None Detected	0	0	0.0043	<13.00	<0.0043

Analyst(s)

Larry Kolk (4)

Michael DeCavallas, Laboratory Manager
or other approved signatory

LA Testing is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above and may not be reproduced except in full, without written approval by LA Testing. This test report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. LA Testing bears no responsibility for sample collection activities or analytical method limitations. Sample received in acceptable condition unless otherwise noted. Samples received in good condition unless otherwise noted.

Samples analyzed by LA Testing Huntington Beach, CA

Initial report from: 12/01/2018 13:21 PM